

June 3, 2008

NORWESCO, INC.
 ANASTASIA R. O'HARA

PO BOX 439
 ST BONIFACIUS MN 55375-0439

Re: Description: SEWAGE TANKS, POLYETHYLENE
 Manufacturer: NORWESCO, INC.
 Product Name: PUMP TANK
 Model Number(s): 500 GALLON SPHERE (PART NO. 40785)
 (46.5" L.L., 30" MAX. DEPTH OF BURY, SEE STIPULATIONS FOR GALLONS PER INCH)
 Product File No: 20080280

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of FEBRUARY 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- A permanent warning label that conforms to s. Comm 84.25 (8), Wis. Adm. Code, must be attached to the cover of this product.
- The gallon capacity per inch of the NORWESCO 500 gallon dose tank is shown in the table below.

Height from pump base	Gallons capacity	Height from pump base	Gallons capacity	Height from pump base	Gallons capacity
1	13	17	185	33	410
2	20	18	199	34	422
3	28	19	213	35	434
4	36	20	227	36	445
5	45	21	242	37	456
6	54	22	256	38	466
7	64	23	271	39	476
8	74	24	295	40	485
9	85	25	308	41	594
10	96	26	321	42	503
11	108	27	335	43	511
12	120	28	348	44	518
13	133	29	361	45	525
14	145	30	373	46	531
15	158	31	386	47	537
16	172	32	398		

This approval supersedes the approval issued on 2/19/2003 under product file number 20020518.

NORWESCO, INC.
Page 2
June 3, 2008
PRODUCT FILE NO. 20080280

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20020518.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov